

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd – trading as AWTA Product Testing

A.B.N. 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O. Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

## TEST REPORT

CLIENT : QUEST CARPET MANUFACTURERS P/L  
PO BOX 4056  
DANDENONG SOUTH VIC 3175

TEST NUMBER : 7-597772-JV  
ISSUE DATE : 11/06/2014  
PRINT DATE : 11/06/2014

SAMPLE DESCRIPTION Clients Ref: "Canadian Bay"  
Tufted loop pile carpet  
Nominal Composition: Polyester  
Nominal Mass: pile 620g/m<sup>2</sup>  
Nominal Thickness: pile 3.5mm  
Colour: Grey

AS/NZS 4586-2013  
APPENDIX A

Slip Resistance of New Pedestrian Surface Materials  
Wet Pendulum Test Method

Specimen	1	2	3	4	5	SRV
British Pendulum Number	69	69	69	66	69	68
Classification	P5 - Surface tested dry					
Sampling and direction of test	Sampling conducted by client					
Preparation:	As received, without underlay					
Fixed / Unfixed	Unfixed					
Air Temperature	22degC					

Test equipment: Munroe Stanley Skid Resistance Tester  
(Pendulum) Serial Number 0320

Slider rubber: Slider 96 Batch No 53, prepared on a P400  
and 3um lapping film

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance to be checked

TESTED BY ATTAR

207633

1

( END OF REPORT )

PAGE 1

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the name AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.

