## AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N. 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O. Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## TEST REPORT

QUEST CARPET MANUFACTURERS P/L CLIENT :

PO BOX 4056

DANDENONG SOUTH VIC 3175

TEST NUMBER : 7-597774-JV

ISSUE DATE : 11/06/2014

PRINT DATE : 11/06/2014

SAMPLE DESCRIPTION

Clients Ref: "Crossley Grey" Tufted cut pile carpet Nominal Composition: Nylon Nominal Mass: pile: 1360g/m2 Nominal Thickness: pile: 6.3mm

Colour: Grey

AS/NZS 4586-2013 APPENDIX A

Slip Resistance of New Pedestrian Surface Materials Wet Pendulum Test Method

1

Specimen British Pendulum Number

Classification

Sampling and direction

of test Preparation:

Fixed / Unfixed Air Temperature

2

69 65 66 60 53 P5 - Surface tested dry

Sampling conducted by client As received, without underlay

3

4

5

SRV

63

Unfixed 22degC

Test equipment:

Munroe Stanley Skid Resistance Tester

(Pendulum) Serial Number 0320

Slider rubber: Slider 96 Batch No 53, prepared on a P400

and 3um lapping film

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance to be checked

TESTED BY ATTAR

207631

1 C

53.00

END OF REPORT

PAGE 1

© Australian Wool Testing Authority Ltd Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the name AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of





MANAGING DIRECTOR

)