

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

## TEST REPORT

**Client :** Quest Carpet Manufacturers Pty Ltd  
43-55 Mark Anthony Drive  
Dandenong South VIC 3175

**Test Number :** 20-005581  
**Issue Date :** 23/11/2020  
**Print Date :** 23/11/2020

**Sample Description** Clients Ref : "Hemisphere"  
Cut pile carpet  
Colour : Beige  
End Use : Flooring  
Nominal Composition : Solution Dyed Polyester  
Nominal Thickness : 12mm

AS 4586-2013  
Appendix A

### Slip Resistance Classification of New Pedestrian Surface Materials Dry Pendulum Test Method

Date of Testing 23/11/2020  
Test Temperature 22 °C  
Sample Preparation Tested as recieved without underlay.  
Pile Direction Length  
Fixed/Unfixed Unfixed  
Slider No 96 Batch No 95

Length	1	2	3	4	5	SRV
British Pendulum Number	76	75	75	75	76	75
Classification (Surface tested dry)						P5

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

221433

47582

Page 1 of 1

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR

0204/11/06